



ANALYTICAL SERVICE GROUP
Organic & inorganic analysis
Advanced microanalysis
Trace contaminant identification
Environmental assessment
Polymer and material science

WATER QUALITY ANALYTICAL REPORT

TOTAL HOUSE INSPECTIONS
ATTENTION: TOTAL HOUSE INSPECTION
REPORTED VIA EMAIL [REDACTED]

RE: [REDACTED]
SITE ADDRESS [REDACTED]
TEST OBJECTIVE :E. COLI, TOTAL COLIFORM, LEAD, ARSENIC, NITRITE-N & NITRATE-N
METHOD :APHA MEMBRANE FILTRATION, GF-AAS, HACH TNT+ 835 & 839
SAMPLE DESCRIPTION :DOMESTIC WATER - SINK 2ND FLOOR
SAMPLED BY, DATE AND TIME :TOTAL HOUSE INSPECTION 07/17/26 11:30
ABSOLUTE LAB I.D.# :26.01030.4561
DATE AND TIME RECEIVED :07/17/26 @ 12:15
DATE REPORTED :07/21/26

TEST DATA SECTION

PARAMETER	TEST RESULT	MAXIMUM CONTAMINANT LEVEL
<i>Escherichia coli</i>	0 COLONIES/100ml	0 COLONIES/100ml
Total coliform	0 COLONIES/100ml	0 COLONIES/100ml
Nitrite-N	<0.2 mg/L	1 mg/L
Nitrate-N	4.1 mg/L	10 mg/L
Lead - Pb	<0.002 mg/L	0.010 mg/L
Arsenic - As	<0.005 mg/L	0.010 mg/L

REPORT INTERPRETATION

To evaluate your water test results consult the Maximum Contaminant Level (M.C.L.) under the right column. If the test result exceeds the M.C.L., then the water is not acceptable based upon that criteria.

Based upon the above criterion your water: **PASSED**

It is a pleasure to provide this service. We note that the data is for informational purposes and is not intended for compliance purposes. If you have questions please direct them to our email address given below.

Absolute Labs INC.

